
Fieldbus System

(For Input/Output)



IP65





AIDA*1 specifications compliant

Push Pull connectors One-touch mounting/removal allows for reduced labor.





*1 Abbreviation of the Automation Initiative of German (Deutschland) Automobile Manufacturers

General-purpose connectors







Compatible with the PROFlenergy energy-saving function



PROFINET



Generally, after factory facilities are shut down, it takes a lot of time to restart them.


PROFlenergy enables PROFINET communication to continue while saving energy by minimizing restart times. When the commands for PROFlenergy energy-saving mode are sent from the I/O controller (PLC) to the I/O device (SI unit), information regarding downtimes is also sent (such as lunch breaks, nighttime, weekends, and holidays).

SMC SI units do not require time for restarting. However, for the connected I/O equipment, such as pressure switches, flow switches, auto switches, and valves, 3 types of energy-saving modes are available for customers to choose from depending on the application.

Mode	Output (Valve/Digital)	Input device (Pressure switch, flow switch, auto switch, etc.)	Input data
Shut down/Clear value mode	OFF	OFF (Power supply)	OFF
Shut down/Hold last value mode	Hold	OFF (Power supply)	Hold
PROCEED mode	Hold	Hold	Hold


Shared Device function

An I/O module connected to an SI unit can be controlled by multiple I/O controllers (PLC).



- Information can be shared with up to 3 controllers in addition to the control PLC.
- The cost of the hardware, cables, and installation space can be reduced.

PLC ① to ③: For monitoring PLC ④ : For control



^{*} The Shared Device function enables an I/O module connected to the I/O device to be controlled by multiple I/O controllers (PLC). The control status can be shared among other I/O controllers. As the function can be used across the entire PROFINET line, the cost for hardware, cables, and installation space can be reduced.




MRP/MRPD function



MRP (Media Redundancy Protocol) function

Communication can be continued even if one of the communication cables in the network is disconnected or damaged. Furthermore, as it is possible to identify the disconnection point quickly, the network disconnection time can be kept within 200 ms

* In order to use the MRP function, the PLC must be able to support it.



MRPD (Media Redundancy for planned duplication) function

It is possible to duplicate routes with a ring topology configured with PROFINET IRT communication.

Communication reconnection time is faster than with the MRP function, so communication can be continued without recovery time.


NET Load Class III compatible

PROFINET

Passed and certified under the highest network load (Class ■) specified by PROFINET.

Built-in web server function, FW (firmware) updates

PROFINET



Connection example

All products are accessible via PC.

• FW updates • Status checks • Forced outputs, etc.



- The status (errors and diagnostic contents) of all products can be checked via web browser.
- Easy operation testing, initial operation checking of equipment, and maintenance without a PLC




- Batch firmware updating for up to 255 units is possible from the Ethernet line.
- ●Easy to handle future version upgrades

Dual communication and dual power connectors



PROFIsafe

- 2 power connectors and 2 communication connectors are mounted, making daisy-chain connection possible.
- An external branch connector is not necessary.
 Reduced wiring space
- Loop through current between power connectors:
 Max. 16 A*1
- * The max. allowable current for the 7/8 inch power supply connector is 10 A. The max. loop through current between connectors is 6 A.





Fast Start Up function

PROFINET


Time from power ON to communication connection:

Approx. 10 s

function In the case of a tool changer, it takes about 10 seconds for communication to be connected in some products after the power to the device installed on the tool is turned ON.

For products which support the Fast Start Up function, communication can be operational even faster.

* In order to use the Fast Start Up function, the PLC must be able to support it.



Tool 2

Tool 3

PROFIsafe

PROFIsafe


Fiber-optic cable maintenance alarm

for the Fast Start Up

> **PROFINET** * Available for the EX245-SPN1A and the EX245-FPS1

> > **PROFINET**

This feature continuously monitors the received light intensity from the fiber-optic cable and reports it to the PLC. Any loss of intensity is an indicator of damage to the cable, so may give a warning before communication is lost. By using preventative maintenance, you can avoid unexpected shutdowns.



Modules can be combined flexibly.

Number of valves, digital inputs/outputs

Solenoid valve	Max. 32 valves
Digital input	Max. 128 inputs
Digital output	Max. 64 outputs

- I/O modules can be connected and removed one by one.
- Up to 8 modules can be connected in any order.

Digital input module Digital output module

Connectable Valve Series

	Series			Flow rate characteristics	s (4/2 → 5/3)	Max. number	Power consumption	Applicable
	Series			C [dm³/(s⋅bar)]	b	of solenoids	[W]	cylinder size
IP65			JSY3000	2.77	0.27	00	0.4 (Standard)	ø50
IP05		((JSY5000	6.59	0.22	32	0.1 (With power-saving circuit)	ø80
IP65	THE PARTY OF THE P	•	SY3000	1.6	0.19	20	0.35 (Standard)	ø50
11-05		6	SY5000 3.6 0.17	32	0.1 (With power-saving circuit)	ø63		
			VQC2000	3.2	0.30		0.4 (Standard)	ø63
IP65	P65		VQC4000	7.3	0.38	24	0.95 (Standard) 0.4 (Low-wattage type)	ø160

- *1 For models other than the applicable models, please contact your SMC sales representative.
- *2 The use of validated products may be required for valve manifolds used in the safety-related parts of equipment which is compliant with international standard ISO 13849. For validated products, please contact your SMC sales representative.

Supports safety communication (PROFIsafe)


PROFIsafe



PROFIsafe is established as an international standard (IEC 61784-3-3). It is a communication protocol that transmits safety-related data by PROFINET communication and can be used up until safety standards ISO 13849-1 PL e and IEC 61508/IEC 62061 SIL 3.



The PROFINET/PROFIsafe compatible PLC allows for PROFINET and PROFIsafe compatible SI units to be mixed on one communication line.



Compliant with safety standards

PROFIsafe

The aim is to facilitate a safe design (featuring ISO/IEC compliance) of the customer's equipment and facilities. The EX245-FPSD has been certified under the following categories by a third-party organization (TÜV Rheinland).



IEC 61508/IEC 62061 SIL 3 ISO 13849 PL e/Cat. 4

- · SIL (Safety Integrity Level)
- A safety integrity level as defined by international standard IEC 61508/62061 There are 4 levels of safety, with the lowest being SIL 1 and the highest being SIL 4.
- · PL (Performance Level)


A scale used to define the capability of safety-related parts to perform a safety function as defined by international standard ISO 13849

There are 5 levels of safety function, with the lowest being PL a and the highest being PL e.


Safety Output

PROFIsafe

The EX245-FPS□ has safety outputs inside the product that can control 3 zones for valves and 1 zone for output modules individually. When the safety switch is turned OFF by directive from the PLC, the voltage supplied to the valve or output module is shut off, and it switches to safe state. The safety switch of this product has two redundancies, one on the 24 V side and the other on the 0 V side. It continuously runs diagnostics. The safety switch is turned OFF in the event of an error detection.



The valve/actuator will not turn ON when the PROFIsafe signal is OFF, even if an ON instruction is given via PROFINET signal. Only when both PROFINET and PROFIsafe instruct the device to turn ON will the valve/actuator turn ON.



▲ Safety Definition

The safe state of the EX245-FPS is a condition in which the safety output described above is turned OFF to shut off the supply of power to the valve manifold.

This product does not cover valve manifolds that are being used in connection with this product or the safety function and safe state of electric/air equipment that includes a peripheral circuit.

Safety Input

PROFIsafe


The EX245-FPS□ is equipped with safety inputs. The safety inputs of this product can connect to components (e.g. laser scanners, light curtains, etc.) that are compatible with the safety inputs.

The safety input can be loaded in 2 ways:

- Single channel (1 out of 1): 8 safety inputs (SIL 2/PL d)
- Dual channel (1 out of 2): 4 safety inputs (SIL 3/PL e)









Safety Input (PROFIsafe compatible models)

PROFIsafe







⚠Safety of the machine or system

The manufacturer of the machine/system and its user are responsible for the safety of the machine/system. Use of the EX245-FPS \square requires machine/system safety concepts which are in accordance with the corresponding directives and standards, safety function validation, and hazard and risk analysis. Target SILs (IEC 61508/62061 compliance) and performance levels/categories (ISO 13849 compliance) are determined based on the risk analysis. For more information, refer to the "Safety of the machine or system" section in the operation manual of the EX245-FPS \square .


CONTENTS


Fieldbus System (For Input/Output) EX245 Series














Construction p. How to Order p. Specifications p. Dimensions/Parts Description p. 1 Assembly Examples p. 1	9
Accessories	
1 Seal Capp. 1	5
2 Marker p. 1	
3 Joint Packp. 1	5
4 7/8 Inch Connector and Related Partsp. 1	5
5 Communication Cable/Connector ·····p. 1	6
6 Field-wireable Communication Connectorp. 1	7
7 I/O Cable with Connector,	
I/O Connector ·····p. 1	8
Charifia Bradust Bragautions	



















Fieldbus System For Input/Output









SI Unit

EX245-SPN1A







Connector type

Symbol	Protocol	Communication connector	Power supply connector
SPN1A		Push Pull connector (SCRJ): 2 pcs.	Push Pull connector (24 V): 2 pcs.
SPN2A	PROFINET	Push Pull connector (RJ45): 2 pcs.	Push Pull connector (24 V): 2 pcs.
SPN3A		M12 connector (4-pin, Socket, D-coded): 2 pcs.	7/8 inch connector (5-pin, Plug): 1 pc. 7/8 inch connector (5-pin, Socket): 1 pc.
FPS1		Push Pull connector (SCRJ): 2 pcs.	Push Pull connector (24 V): 2 pcs.
FPS2	PROFIsate	Push Pull connector (RJ45): 2 pcs.	Push Pull connector (24 V): 2 pcs.
FPS3		M12 connector (4-pin, Socket, D-coded): 2 pcs.	7/8 inch connector (5-pin, Plug): 1 pc.





EX245-FPS1 EX245-FPS2

EX245-FPS3

Digital Input Module

EX245-DX1



Digital input module specification DX1 Digital input (16 inputs)

Digital Output Module

EX245-DY1



Digital output module specification

DY1 Digital output (8 outputs)

End Plate

EX245-EA2-1





Bracket

For VQC

Bracket General-purpose 2 Without bracket For JSY/SY 3 (Only for EX245-SPN□A) For VQC4000 4 (Only for EX245-SPN□A) For VQC2000 5 (Only for EX245-SPN□A)

- * For the EX245-EA2-3/4/5, only the EX245-SPN□A can be connected. The bracket is adjusted according to the mounting hole pitch of the manifold valves.
- * Refer to the Web Catalog for manifold valve part numbers. If you are considering using a manifold valve compatible with PROFIsafe, be sure to check with your SMC sales representative prior to ordering.




Specifications

Common Specifications for All Units/Modules

Item	Specifications
Operating temperature range	Operating: -10 to 50°C, Stored: -20 to 60°C (No condensation)
Operating humidity range	Operating, Stored: 35 to 85% RH (No condensation)
Withstand voltage	500 VAC for 1 minute between external terminals and FE
Insulation resistance	500 VDC, 10 M Ω or more between external terminals and FE
Enclosure	IP65 (Manifold assembly, With seal cap)
Standards	CE marking (EMC directive/RoHS directive), UL (CSA)

SI Unit Specifications

31 (Unit Specificati	0115				
	Model		EX245-SPN1A	EX245-SPN2A	EX245-SPN3A	
	Protocol		PROFINET			
_	Device type		PROFI	NET IO		
유	Communication sp	eed	100 Mbps	full duplex		
<u>8</u>	Configuration file*1		GSE) file		
Communication	Applicable function	1	MRP function, MRPD function, Fast Start Up function, Shared Device function, PROFlenergy function, Web server function, FW update function, Conformance Class C, NET Load Class II			
			Fiber-optic cable maintenance alarm	enance alarm —		
ल	Internal current consu	ımption (US1)	300 mA or less	200 mA or less		
Ξ̈́	Loop through current between	power connectors	16 A	6 A		
Electrical	Operating voltage/	US1	24 VDC +20%, -15%/6 A			
Ш	Max. current	US2	24 VDC +20%, -15%/4 A			
	Output type		Source/PNP (Negative common)			
Ħ	Number of outputs		32 outputs			
Output	Load		Solenoid valve with surge voltage suppressor of 24 VDC, 1 W or less (SMC)			
ō	Power supply		24 VDC, 2 A			
	Protection		Short-circuit protection			
<u>=</u>	Max. number of mo	dules	8			
General	Max. number of dig	ital inputs	128			
l e	Max. number of dig	ital outputs	64			
၂ ၒ	Weight		465 g 540			



	Model			EX245-FPS2	EX245-FPS3		
E C	Protocol		PROFINET, PROFIsafe				
atic	Device type		PROFINET IO				
<u>:</u>	Communication sp	eed	100 Mbps	full duplex			
Communication			MRP function, Con	formance Clas	s C,		
Ē	Applicable function	1	NET Load	d Class I			
			Fiber-optic cable maintenance alarm	_	_		
Electrical	Internal current consu	ımption (US1)	350 mA or less	300 mA	or less		
i.	Loop through current between	power connectors	16 A		10 A		
ec	Operating voltage/	US1	24 VDC +20°	%/–15%, 6 A			
Ĭ	Max. current	US2	24 VDC +20%/-15%,	4 A (Excludes	valves)		
	Number of inputs		Dual channel: 4 inputs,	Single channel	: 8 inputs		
	External supply vol	tage	24 VDC +2	20%/–15%			
<u>+</u>	Max. supply curren		UT1: 2 A,	UT2: 1 A			
Safety input	Cross-circuit detec		Ye	es			
ï	Over current/Short-circuit d	etection function	Yes				
et)	Input type		PNP				
Saf	ON voltage		11 to 30 V				
0,	OFF voltage		–3 to 5 V				
	Input current (at 24		Typ. 3.8 mA				
	Input characteristic		Type 3 (IEC 61331)				
Ħ	Number of safety	Valve side	3 zones				
횬	outputs	Module side	1 zone				
٥ ا	Max. current	Valve side	1.5 A (Total of 3 zones)				
Safety output		Module side	4 A				
afe	Short-circuit protect		Yes				
o	Power supply source	ce	_	S2			
	Output type		PNP				
Ĭ	Number of outputs		8 outputs/zone, Total of 24 outputs				
Output	Load		Solenoid valve with surge voltage suppressor of 24 VDC, 1 W or less (SMC)				
0	Protection		Short-circuit protection				
	Power supply			C, 1.5 A			
ā	Max. number of mo		8				
Jer	Max. number of dig			28			
General	Max. number of dig	ital outputs	-	4			
_	Weight		1,100 g	1,200 g			

^{*} The configuration file can be downloaded from the SMC website: https://www.smcworld.com



EX245-SPN1A



EX245-SPN2A



EX245-SPN3A




EX245-FPS1




EX245-FP52



EX245-FPS3



Manifold wiring example




			Y				
Pin	Valve	Signal	Function				
no.	zone name		Function				
1	_	MOUTA	0 01/				
2	Common	M OUT1	Common 0 V				
3		Z OUT1	Zone 1: Safety output				
4	Zone 1	SOL0	Output 0 (Output is available only when Zone 1 is turned ON.)				
i		:	:				
11		SOL7	Output 7 (Output is available only when Zone 1 is turned ON.)				
12		Z OUT2	Zone 2: Safety output				
13	Zone 2	SOL8	Output 8 (Output is available only when Zone 2 is turned ON.)				
:	Zone Z	:	:				
20		SOL15	Output 15 (Output is available only when Zone 2 is turned ON.)				
21		Z OUT3	Zone 3: Safety output				
22	Zone 3	SOL16	Output 16 (Output is available only when Zone 3 is turned ON.)				
:		:					
29		SOL23	Output 23 (Output is available only when Zone 3 is turned ON.)				

		2	one	1			Z	one	2			Z	one	3	
Pin no.	3	4	6	8	10	12	13	15	17	19	21	22	24	26	28
Signal name	Z OUT 1	SOL 0	SOL 2	SOL 4	SOL 6	Z OUT 2	SOL 8	SOL 10	SOL 12	SOL 14	Z OUT 3	SOL 16	SOL 18	SOL 20	SOL 22
Station no.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
Signal name	_	SOL 1	SOL 3	SOL 5	SOL 7	_	SOL 9	SOL 11	SOL 13	SOL 15	_	SOL 17	SOL 19	SOL 21	SOL 23
Pin no.		5	7	9	11		14	16	18	20		23	25	27	29
Wiring specifications	Single	Double	Double	Double	Double	Single	Double	Double	Double	Double	Single	Double	Double	Double	Double

(Example) The stations corresponding to the safety outputs (Z OUT n) are configured by single wiring.

Specifications





^{*1} An M12 (4-pin) connector can also be connected.



EX245-DX1

EX245-DY1





Digital Output Module

Model	EX245-DY1	
Output type	PNP	
Output connector	M12 (5-pin) socket*1	
Number of outputs	8 outputs	
Supplied voltage	24 VDC	
Max. load current	0.5 A/Output, 2 A/Module	
Protection	Short-circuit protection	
consumption	50 mA or less	
	280 g	
	Output type Output connector Number of outputs Supplied voltage Max. load current Protection	

^{*1} An M12 (4-pin) connector can also be connected.

End Plate

Model	EX245-EA2-1	EX245-EA2-2	EX245-EA2-3	EX245-EA2-4	EX245-EA2-5
Bracket	Yes	No	Yes	Yes	Yes
Weight	120 g	80 g	120 g	150 g	120 g
Note	General-purpose	_	Mounting hole for JSY/SY	Mounting hole for VQC4000	Mounting hole for VQC2000


^{*} For the EX245-EA2-3/4/5, only the EX245-SPN□A can be connected. The bracket is adjusted according to the mounting hole pitch of the manifold valves.




EX245 Series

Dimensions/Parts Description

SI Unit






EX245-FPS1/2

37

19

90

30




Push Pull connector


EX245-SPN1A: SCRJ EX245-SPN2A: RJ45

Power supply connector

Push Pull connector (24 V)



EX245-FPS3







Dimensions/Parts Description

Digital Input Module


EX245-DX1






Digital Output Module

EX245-DY1






EX245 Series


Dimensions/Parts Description


End Plate


EX245-EA2-1




EX245-EA2-2









EX245-EA2-3 (For JSY/SY)






EX245-EA2-4 (For VQC4000)




EX245-EA2-5 (For VQC2000)



Assembly Examples


Manifold valve
SI unit — EX245-SPN1A
Digital input module — EX245-DX1
Digital output module — EX245-DY1
End plate — EX245-EA2-3

* If you are considering using a manifold valve compatible with PROFIsafe, be sure to check with your SMC sales representative prior to ordering.



- $\ast 1~$ A tightening tool is not included. It should be provided by the customer.
- *2 The joint and modular adapter are shipped together with the digital input/output modules and end plate.

EX245 Series **Accessories**



Seal Cap (10 pcs.)

Be sure to mount a seal cap on any unused I/O connectors. Otherwise, the specified enclosure cannot be maintained.

EX9-AWTS For M12 (10 pcs.)



EX245-AWC For communication connectors (10 pcs.)




EX245-AWP For power supply connectors (10 pcs.)



Seal cap for communication connector and power supply connector are included when EX245-SPN1A/2A or FPS1/2 is shipped (2 caps for each unit).


Joint Pack



Included when **EX245-DX1/DY1**, **EA2-**□ are shipped.

2 Marker (1 sheet, 88 pcs.)

The signal name of I/O device and each module name can be entered and mounted on each module.




4 7/8 Inch Connector and Related Parts

· Power supply cable (7/8 inch connector) PCA-1558810 Straight 2 m

PCA-1558823





5 Communication Cable/Connector

EX9-AC 005 EN-PSPS (With connector on both sides (Plug/Plug))

Cable length (L)

005 500 mm

010 1000 mm


020 2000 mm

030 3000 mm

050 5000 mm

100 10000 mm

Item	Specifications
Cable O.D.	ø6.5 mm
Conductor nominal cross section	0.34 mm ² /AWG22
Wire O.D. (Including insulator)	1.55 mm
Min. bending radius (Fixed)	19.5 mm



EX9-AC 005 EN-PAPA (With angled connector on both sides (Plug/Plug))

Cable length (L)

005 500 mm

010 1000 mm


020 2000 mm

030 3000 mm

050 5000 mm


100 10000 mm

Item	Specifications
Cable O.D.	ø6.5 mm
Conductor nominal cross section	0.34 mm ² /AWG22
Wire O.D. (Including insulator)	1.55 mm
Min. bending radius (Fixed)	19.5 mm



PCA-1446566 (Plug)

Item	Specifications
Cable O.D.	ø6.5 mm
Conductor nominal cross section	AWG22
Wire O.D. (Including insulator)	1.55 mm
Min. bending radius (Fixed)	45.5 mm




EX245 Series

5 Communication Cable/Connector

EX9-AC 020 EN-PSRJ (Plug/RJ-45 connector) M12 Metal parts Metal parts Cable length (L) RJ-45 010 1000 mm 020 2000 mm 030 3000 mm 47.3 050 5000 mm 100 10000 mm Terminal Core wire Terminal Signal name White/Orange TD+ 1 2 3 4 Orange White/Green RD+ 0000 2 3 4 5 6 7 TD-RD-Plug connector Plug connector pin arrangement pin arrangement Metal parts Item Specifications **D-coded** Cable O.D. ø6.4 mm 0.14 mm²/AWG26 Conductor nominal cross section Shield Metal parts Wire O.D. (Including insulator) 0.98 mm


6 Field-wireable Communication Connector

26 mm



Min. bending radius (Fixed)





Connections (Straight cable)

Applicable Cable


Item	Specifications	
Cable O.D.	4.0 to 8.0 mm	
Wire gauge (Stranded wire cross section)	0.14 to 0.34 mm ² /AWG26 to 22	

^{*} The table above shows the specifications for the applicable cable. Adaptation for the connector may vary on account of the conductor construction of the electric wire.

1/O Cable with Connector, I/O Connector

Name	Use	Part no.	Description
Cable with For sensor	PCA-1557769	Cable with M12 connector (4 pins/3 m)	
connector		PCA-1557772	Cable with M8 connector (3 pins/3 m)
Field-wireable connector	PCA-1557730	Field-wireable connector (M8/3 pins/Plug/Piercecon® connection)	
	PCA-1557743	Field-wireable connector	
	P	PCA-1557756	(M12/4 pins/Plug/QUICKON-ONE connection/SPEEDCON)
Y connector For sensor	For concer As P	PCA-1557785	Y connector (2 x M12 (5 pins)-M12 (5 pins)/SPEEDCON)
	PCA-1557798	Y connector (2 x M8 (3 pins)-M12 (4 pins)/SPEEDCON)	

* When using the Y connector, connect it to the connector on the I/O module through the sensor cable with the M12 connector (PCA-1557769).





EX245 Series Specific Product Precautions

Be sure to read this before handling the products. Refer to the back cover for safety instructions. For fieldbus system precautions, refer to the "Operation Manual" on the SMC website: https://www.smcworld.com

Operating Environment

⚠ Caution

1. Select the proper type of enclosure according to the operating environment.

IP65 is achieved when the following conditions are met.

- 1) Provide appropriate wiring of the electrical wiring cables, communication connectors, and cables with M12 connectors.
- Appropriately mount the SI unit, each module, and the manifold valve.
- 3) Be sure to mount a seal cap on any unused connectors. If using in an environment that is exposed to water splashes, please take measures such as using a cover.



⚠ Safety Instructions

These safety instructions are intended to prevent hazardous situations and/or equipment damage. These instructions indicate the level of potential hazard with the labels of "Caution," "Warning" or "Danger." They are all important notes for safety and must be followed in addition to International Standards (ISO/IEC)*1), and other safety regulations.

Caution: Caution indicates a hazard with a low level of risk which, If not avoided, could result in minor or moderate injury.

Warning: Warning indicates a hazard with a medium level of risk which, if not avoided, could result in death or serious injury.

⚠ Danger: Danger if not avoided, will result in death or serious injury. **Danger** indicates a hazard with a high level of risk which, *1) ISO 4414: Pneumatic fluid power - General rules relating to systems.

ISO 4413: Hydraulic fluid power – General rules relating to systems.

IEC 60204-1: Safety of machinery - Electrical equipment of machines. (Part 1: General requirements)

ISO 10218-1: Manipulating industrial robots - Safety.

⚠Warning

1. The compatibility of the product is the responsibility of the person who designs the equipment or decides its specifications.

Since the product specified here is used under various operating conditions, its compatibility with specific equipment must be decided by the person who designs the equipment or decides its specifications based on necessary analysis and test results. The expected performance and safety assurance of the equipment will be the responsibility of the person who has determined its compatibility with the product. This person should also continuously review all specifications of the product referring to its latest catalog information, with a view to giving due consideration to any possibility of equipment failure when configuring the equipment.

2. Only personnel with appropriate training should operate machinery and equipment.

The product specified here may become unsafe if handled incorrectly. The assembly, operation and maintenance of machines or equipment including our products must be performed by an operator who is appropriately trained and experienced.

- 3. Do not service or attempt to remove product and machinery/ equipment until safety is confirmed.
 - 1. The inspection and maintenance of machinery/equipment should only be performed after measures to prevent falling or runaway of the driven objects have been confirmed.
 - 2. When the product is to be removed, confirm that the safety measures as mentioned above are implemented and the power from any appropriate source is cut, and read and understand the specific product precautions of all relevant products carefully.
 - 3. Before machinery/equipment is restarted, take measures to prevent unexpected operation and malfunction.
- 4. Contact SMC beforehand and take special consideration of safety measures if the product is to be used in any of the following conditions.
 - 1. Conditions and environments outside of the given specifications, or use outdoors or in a place exposed to direct sunlight.
 - 2. Installation on equipment in conjunction with atomic energy, railways, air navigation, space, shipping, vehicles, military, medical treatment, combustion and recreation, or equipment in contact with food and beverages, emergency stop circuits, clutch and brake circuits in press applications, safety equipment or other applications unsuitable for the standard specifications described in the product catalog.
 - 3. An application which could have negative effects on people, property, or animals requiring special safety analysis.
 - 4. Use in an interlock circuit, which requires the provision of double interlock for possible failure by using a mechanical protective function, and periodical checks to confirm proper operation.

⚠ Caution

1. The product is provided for use in manufacturing industries.

The product herein described is basically provided for peaceful use in manufacturing industries.

If considering using the product in other industries, consult SMC beforehand and exchange specifications or a contract if necessary.

If anything is unclear, contact your nearest sales branch.

Limited warranty and Disclaimer/ **Compliance Requirements**

The product used is subject to the following "Limited warranty and Disclaimer" and "Compliance Requirements".

Read and accept them before using the product.

Limited warranty and Disclaimer

- 1. The warranty period of the product is 1 year in service or 1.5 years after the product is delivered, whichever is first.*2) Also, the product may have specified durability, running distance or
- replacement parts. Please consult your nearest sales branch. 2. For any failure or damage reported within the warranty period which is clearly our responsibility, a replacement product or necessary parts will be provided.

This limited warranty applies only to our product independently, and not to any other damage incurred due to the failure of the product.

- 3. Prior to using SMC products, please read and understand the warranty terms and disclaimers noted in the specified catalog for the particular products.
 - 2) Vacuum pads are excluded from this 1 year warranty.

A vacuum pad is a consumable part, so it is warranted for a year after it is delivered.

Also, even within the warranty period, the wear of a product due to the use of the vacuum pad or failure due to the deterioration of rubber material are not covered by the limited warranty.

Compliance Requirements

- 1. The use of SMC products with production equipment for the manufacture of weapons of mass destruction (WMD) or any other weapon is strictly prohibited.
- 2. The exports of SMC products or technology from one country to another are governed by the relevant security laws and regulations of the countries involved in the transaction. Prior to the shipment of a SMC product to another country, assure that all local rules governing that export are known and followed.

⚠ Caution

SMC products are not intended for use as instruments for legal metrology.

Measurement instruments that SMC manufactures or sells have not been qualified by type approval tests relevant to the metrology (measurement) laws of each country. Therefore, SMC products cannot be used for business or certification ordained by the metrology (measurement) laws of each country.

Revision History

- Edition B * A PROFIsafe compatible product has been added.
 - * Number of pages has been increased from 16 to 24.

ZR

↑ Safety Instructions Be sure to read the "Handling Precautions for SMC Products" (M-E03-3) and "Operation Manual" before use.